


Safety Recall

Hazard:

In certain instances, the product may not detect smoke, which could compromise the alarms' ability to alert consumers to a potential fire.

Brand Name, Model of Affected Product:

Kidde TruSense Smoke and Combination Smoke/Carbon Monoxide Alarms.



Remedy:

Consumers should immediately contact Kidde to request a free replacement unit.



Consumer Contact: Kidde toll-free at

1-844-796-9972

from 8AM to 8PM EST Monday through Friday, 9AM to 3PM EST Saturday, or online at www.kidde.com and click on Product Safety Notices for more information.

Scan code with mobile device for more info



Post through September 30, 2021

In cooperation with the U.S. Consumer Product Safety Commission